

**Bharatiya Vidya Bhavan
(Delhi Kendra)
KG Marg, New Delhi 110 001**

Dated:.....

Company Name: M/s.....

Address:

.....

Mobile /telephone:

Email ID:

Sub: Quotation for supply of 2 Nos. of water coolers (400Ltrs storage Capacities tank) at Bharatiya Vidya Bhavan's Mehta Vidyalaya, KG Marg, New Delhi 110001

On behalf of Bhartiya Vidya Bhavan's Mehta Vidyalaya, sealed quotation are invited from the manufacturers /reputed company for supply two Water Coolers of 400 litre capacity each as per the attached specifications. Please quote your rate in the given format:

S. No.	Description	Unit	Quantity	Rate / Unit	Total Amount	Amount in words
1.	As per attached specifications	Nos.	02			
2.	G.S.T@.....	--	--	--		
3.	Total				Rs.....	(Rupees.....)

Terms & Conditions:

1. The number of items should be supplied within two weeks after receiving the PO.
2. No advance/mobilization payment.

Md 26

3. The payment shall be made against the bill/ invoice and satisfactorily supply of Water Coolers received in good condition at site (Mehta Vidyalaya).
4. Payment shall be made through RTGS or cheque only.
5. Taxes as admissible shall be deducted from the verified bill.
6. *The mentioned quantity may vary up to any extent.*
7. Bharatiya Vidya Bhavan has the right to reject any quotation without assigning any reason.
8. Fire or any theft till its hand over to Bharatiya Vidya Bhavan shall be supplier's responsibility. Insurance/ delivery challan/ road/transport clearance and all related formalities also must be taken care by the supplier

The sealed quotations may be sent to the **Principal, Mehta Vidyalaya, Gate No.2, Bharatiya Vidya Bhavan, Kasturba Gandhi Marg, and New Delhi 110001** latest by **Monday, The 19th September 2022.**

Head (Works Unit)
Bharatiya Vidya Bhavan

A	SPECIFICATION SHEET for Water Coolers/ Chiller Unit		
	PARTICULARS	Unit	Model No:
	Cooling capacity	Ltr/hr	200
	At 10c temperature drop	Ltr/hr	400
	Glasses/hr at rated condition	Ltr/hr	1000
	Storage capacity	Ltr/hr	400
	Power supply		230V,50Hz,1Phase
	Rated current	Amp	9
	Power supply	Watt.	2000
B	Material specification		
	Chillers Tank		SS 304 THK 0.5 mm
C	SHEET METAL PANELS		
	Top Lid		THK-0.8(SS204/304CU)
	Front panel Top/ bottom		THK-0.8(SS204/304CU)
	Rear panel top/ bottom		THK-0.8(SS204/304CU)
	Side panel both side		THK-0.8(SS204/304CU)
	Base plate / inner angel		THK -0.8MM(GPSP SHEET)
	Mask		THK-0.8MM(SS304)
	Drip tray		THK-0.8MM(SS304)
	Bubble top attachment		NO
	Faucet material		BRASS (CR PLATED)
	No of faucet cold water	Nos.	4
	Evaporator		Grooved Copper
	Condenser coil		Hydrophilic Alum. fins (Blue)
	Legs		Nylon
	Water inlet house pipe		Provided (Food Grade)
	Drain pipe		Provided
	Over flow pipe		provided
	Motor make		Rexnord
	Compressor/ make		Emerson / CR 22
	Compressor/ Refrigerant	.mm	Reciprocating R-22
	Dimension		1160x700x1400
	Net weight	Kg	110/ + & -

M. J. 22

2/2